

1 **UK-TYPE EXAMINATION CERTIFICATE**

2 **Component Intended for use on/in a Product or Protective System Intended for use in  
Potentially Explosive Atmospheres  
UKSI 2016:1107 (as amended) – Schedule 3A, Part 1**

3 UK-Type Examination Certificate Number: **BAS22UKEX0089U**

4 Product: **Type 66MK2A Half Coupler**

5 Manufacturer: **Victor Products Ltd**

6 Address: **Unit 3A, Tyne Dock East Side, Port of Tyne, South Shields, Tyne & Wear,  
NE33 5SQ United Kingdom**

7 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 SGS Baseefa, Approved Body number 1180, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in confidential Report No. **21(C)0133**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0:2018 EN 60079-1:2014**

except in respect of those requirements listed at item 18 of the Schedule.

10 The sign “U” is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as the basis for certification of an equipment or protective system.

11 This UK-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

 **I M2 Ex db I Mb**

SGS Baseefa Customer Reference No. **1186**

Project File No. **22/0133**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/sgsbaseefa](http://www.sgs.co.uk/sgsbaseefa)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



0191



R S SINCLAIR  
TECHNICAL MANAGER  
On behalf of SGS Baseefa Limited

13

## Schedule

14

Certificate Number BAS22UKEX0089U

### 15 Description of Product

Type 66MK2A Half Coupler for use at 6600V, 500A (maximum) comprising a compound filled sealing box, made of cast gunmetal, fitted with a cable gland assembly for single wire armoured cable. Access for filling with compound is via two Group I stopper plugs as HSE(M) 88B5160U. The half coupler incorporates an insulator assembly with three main contact tubes and up to six pilot connectors which are crimped to the cable conductors.

There is a mounting face at one end of the unit for connection via contact pins, a sealing ring and appropriate fasteners to any appropriately certified Group I apparatus or component having an interface to BS3905:1995

### 16 Report Number

21(C)133

### 17 Schedule of Limitations

1. The half coupler should not be used with equipment for which the routine pressure test exceeds 10 bar without further assessments or tests.

### 18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
13	LVD type requirements
21 (1)	External effects
21 (2)	Aggressive substances, etc.

### 19 Drawings and Documents

Number	Sheet	Issue	Date	Description
CA146	1&2	2	21/02/22	Marking Drawing
MECS02ATEX5094U				